



COMMONWEALTH OF MASSACHUSETTS
EXECUTIVE OFFICE OF ENERGY & ENVIRONMENTAL AFFAIRS
DEPARTMENT OF ENVIRONMENTAL PROTECTION
Central Regional Office, 627 Main Street, Worcester, MA 01608

DEVAL L. PATRICK
Governor

IAN A. BOWLES
Secretary

TIMOTHY P. MURRAY
Lieutenant Governor

LAURIE BURT
Commissioner

**Acton Water Supply District, Acton, MA
Concord River Basin
Application for a Water Management Act Permit Amendment
Permit #9P4-2-14-002.01**

Acton Water Supply District has applied for a Water Management Act permit amendment to withdraw water from a gravel packed well in the Concord River Basin. Acton Water Supply District is authorized through the Water Management Act (WMA) program to withdraw up to 1.94 million gallons per day through August 2011. The permit amendment will allow the District to withdraw water from an additional withdrawal location, providing increased capacity, redundancy and operational flexibility. The WMA amendment will not authorize an increase in the average yearly withdrawal volume. The District is seeking approval for a maximum pumping rate of 360 gallons per minute (0.518 million gallons per day) from Assabet Well No. 3. The proposed well is located on land formerly owned by W.R. Grace & Co. north of the intersection of Route 62 and High St. The approximate location is:

	Latitude	Longitude
Assabet Well No. 3	42° 26' 50" N	71° 25' 45" W

A copy of this application is available for review at MassDEP, 627 Main St., Worcester, MA. Call the MassDEP Service Center at (508) 792-7683 to arrange an appointment. The application can also be reviewed at the Acton Water Supply District office, 693 Massachusetts Ave., Acton, MA.

Written comments on the granting of a MassDEP WMA permit amendment for this withdrawal location are to be filed within thirty (30) days of publication of this Legal Notice (by November 7, 2008). The written comments are to be submitted to MassDEP, 627 Main St., Worcester, MA 01608, Attention: Barbara Kickham.